


APPENDIX 4.12.1-2

**County of Los Angeles Fire Department response to
Correspondence Regarding Fire Flow, Dated March 19, 2015**

From: Leslie-Thomas, Judith <Judith.Leslie-Thomas@fire.lacounty.gov>
Sent: Thursday, March 19, 2015 8:51 AM
To: Kathleen King
Subject: RE: Request for LACoFD Information

FYI

Judith Leslie-Thomas
L.A. County Fire Dept.
Forestry Division
5823 Rickenbacker Road
Commerce, CA 90040
Phone (323) 890-4330
Fax (323) 890-4335



From: Collins, Wally
Sent: Thursday, March 19, 2015 7:47 AM
To: Leslie-Thomas, Judith
Cc: Cueva, Juan
Subject: RE: Request for LACoFD Information

Good Morning,


The Fire Department sets the fire flow for each individual development (project) based on information provided in Appendix B of the County of Los Angeles Fire Code (Title 32). The fire flow is based on the total square footage of the proposed building(s), the type of construction and if there is an automatic fire sprinkler system to be installed. The Fire Department does not have the specific gallons per minute of a fire hydrant unless the hydrant has been flow tested recently for another project. This information is requested by the Fire Department when reviewing plans for a proposed development. It is the responsibility of the applicant to contact the jurisdictional water purveyor to perform the fire flow test, with the results submitted back to the Fire Department for review.

Wally Collins
Fire Prevention Engineering Assistant II
Land Development Unit - Fire Prevention Division
County of Los Angeles Fire Department
Commerce - (323) 890-4243
wally.collins@fire.lacounty.gov

From: Leslie-Thomas, Judith
Sent: Wednesday, March 18, 2015 9:42 AM
To: Collins, Wally
Cc: Cueva, Juan
Subject: RE: Request for LACoFD Information

Good Morning! Can you please help me with this request, see e-mail below. Thanks

Judith Leslie-Thomas
L.A. County Fire Dept.
Forestry Division
5823 Rickenbacker Road
Commerce, CA 90040
Phone (323) 890-4330
Fax (323) 890-4335



From: Kathleen King [<mailto:KKing@impactsociences.com>]
Sent: Tuesday, March 10, 2015 10:37 AM
To: Camacho, Christie; Leslie-Thomas, Judith
Subject: Request for LACoFD Information

Good Morning-

A couple of months ago Frank Vidales provided me with some information regarding the LACoFD in the City of Azusa. We are currently working on the EIR for the Azusa TOD Specific Plan and have one additional question: can you please confirm the gallons per minute (at 20 pounds per square inch) that each fire hydrant has.

Thanks-

Kathleen King
Staff Planner
Impact Sciences, Inc.
638 E. Colorado Blvd, Suite 301
Pasadena, CA 91101
(626) 564-1500



kking@impactsociences.com
<http://www.impactsciences.com>
Offices throughout California

 Please consider the environment before printing this email.

CONFIDENTIALITY NOTICE: This communication and any attachments are confidential and privileged. They are intended for the sole use of the addressee. If you receive this transmission in error, you are advised that any disclosure, copying, distribution, or the taking of any action in reliance upon the communication is strictly prohibited. Moreover, any such inadvertent disclosure shall not compromise or waive the attorney-client privilege as to this communication or otherwise. If you have received this communication in error, please contact us at my Internet address (kking@impactsociences.com), or by telephone at (805) 437-1900.